

This certificate is valid for Building Regulations & associated technical guidance in force on the date of registration and for the regulations in the countries indicated

## Tuffa UK Limited: Domestic FP30 firestop storage tank cover

### Description of Product

Tuffa UK Limited: Domestic FP30 firestop storage tank cover is for oil storage tanks up to 3500 litres.



### Key Factors Assessed

- Safety in case of Fire

### Validity

This certificate was first issued on 14<sup>th</sup> December 2010 and is valid until 17<sup>th</sup> January 2021

Issue Dated 3<sup>rd</sup> January 2018

## Scope of Registration

This Registered Detail relates to Tuffa UK Limited: Domestic FP30 firestop storage tank cover for oil storage tanks up to 3500 litres. The detail relates to the covering of external sited, domestic tanks subject to the conditions below. The cover will give 30 minutes fire resistance to FP30 rated oil tanks.

For tank capacities above 3500 litres Fire Service consultation should always be sought.

The FP30 cover is only offered as fitted integral fire protection to the Tuffa range of bunded tanks. It is factory applied by a trained Tuffa installation team prior to dispatch.

The cover can be applied to the range of both plastic and steel bunded tanks.

## Conditions of Certificate

The tank is to be situated externally to the building in which the appliance is installed.

The tank installation relates to a single family dwelling only.

The tank is to be installed on or over a non-combustible base that extends out at least 300mm from all sides of the tank, except that if the tank is closer than 300mm to a wall or boundary wall, the base need only extend as far as the wall.

The tank cover, access hatch and pipe penetrations are to be installed in accordance with the guidance contained within WF Report No.180983A issue 3 and Exova Warringtonfire review of assessment report dated 13th March 2009 updated 21st March 2016 and Tuffa Tanks drawing no. TT/FLY/001.

Whilst Warrington Exova testing has identified suitability for internal use in accordance with the specific requirements of BS 5410-1:2014 section 7, this Registered Detail is not intended to cover such installations. Discussion as to suitability should take place with the relevant Building Control team and Fire & Rescue Service.

LABC consider that, Tuffa UK Limited: Domestic FP30 firestop storage tank cover, will meet the functional requirements of the Building Regulations (listed below) if the criteria detailed in this certificate are met;



### The Building Regulations 2010 (as amended) England & Wales

AD B Fire Safety

Note: The products can contribute to meeting this Requirement subject to limitations detailed in Conditions section.

AD J Heat Producing Appliances

Note: The products can contribute to meeting this Requirement subject to limitations detailed in Conditions section.



### The Building Regulations 2010 (as amended) England

AD B Fire Safety

Note: The products can contribute to meeting this Requirement subject to limitations detailed in Conditions section.



### The Building Regulations 2010 (as amended) Wales

AD B Fire Safety

Note: The products can contribute to meeting this Requirement subject to limitations detailed in Conditions section.



### The Building (Scotland) Regulations 2004 (as amended)

If you would like to discuss a specific use of the product in Scotland it will require an additional assessment under the Scottish Building Regulations and accordingly you should contact the LABSS STAS Administrator at [www.labss.org](http://www.labss.org)

## Non-Regulatory Information



### LABC Warranty

This product confirms to the Functional Requirements of the LABC Warranty Technical Manual.

## Supporting Documentation

Bodycote WF Assessment report number 180983A issue 2. The fire performance of Tuffa protective covers to domestic oil storage tanks.

Drawing TT/FLY/001

Exova Warringtonfire review of assessment report No 322283A dated 13th March 2009, issue 3 updated 21st March 2016 and valid until 1st April 2021

Michael Turner Associates Jointing methods for barrier material

## Contact Information

Tuffa Tanks

Dovefields Industrial Estate

Derby Road

Uttoxeter

Staffordshire

ST14 8SW

Tel: 01889 567 700

Email: [sales@tuffa.co.uk](mailto:sales@tuffa.co.uk)

Web: [www.tuffa.co.uk](http://www.tuffa.co.uk)